

Dr. Ralph DerraÖffentlich bestellter und vereidigter Sachverständiger für
Verpackungsmaterialien, Boden- und Luftanalysen;
Sachverständiger in der Wasseranalytik18 December 2015
Dr. Dr/Bie-schu**EXPERT'S OPINION****2756 GD 15**for Messrs: Knauf Danoline S/A
Kløvermarksvej 6
9500 Hobro / Denmark


Product: Danocol Medifend

The paint surface distributed as Danocol Medifend by the company mentioned above was examined based on the standard DIN EN ISO 846 Plastics – Evaluation of the action of microorganisms, Method B and B' to evaluate the fungistatic effect against a suspension of mould spores.

The results are summarized in the test report 7605/1 (Sample 4) dated 5 June 2015 of the company ISEGA Forschungs- und Untersuchungsgesellschaft Aschaffenburg, Germany.

The surface of the perforated plasterboard pieces painted with the product that were submitted for analysis showed no apparent growth under microscopic inspection. The product was classified to have a strong fungistatic effect according to the standard.

This expert's opinion consists of 1 page.


Dr. Biester
Dipl.-Biologist
Microbiology